Chapter 1 SCOPE AND ADMINISTRATION

Chapter 1 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 105 – FEES AND PERMITS

Add Sec. 105.1.4 to read:

105.1.4 Annual Operational Fire Permits. All fees for annual operational fire permits under the provisions of Sec. 105.8 of this Chapter shall be due and payable at the time of commencement of occupancy and said permit shall expire no later than twelve (12) months after the date of issuance. Fees for the renewal of such permits shall be due and payable upon the expiration of the prior permit. No permit fee paid hereunder shall be refundable by reason of the cessation of occupancy during the permit period. Every annual permit fee that is not paid within a period of thirty (30) days from the time the same became due is hereby declared to be delinquent, and a penalty of 100% or a maximum fine of five-hundred (500) dollars shall be added to said fee.

Amend Sec. 105.2 to read:

105.2 Application For Permit. Applications for a permit required by this code shall be made to the fire code official in such form and detail as prescribed by the fire code official. Applications for permits shall be accompanied by such plans as prescribed by the fire code official. Said application shall be accompanied by a fee in an amount listed in the City of Santa Clara Municipal Fee Schedule

105.6 REQUIRED OPERATIONAL PERMITS

Amend Table 105.6.8 to read:

TABLE 105.6.8 PERMIT AMOUNTS FOR COMPRESSED GASES¹

TYPE OF GAS	AMOUNT(cubic feet) ²
	X 0.0283 for m ³
Corrosive	200
Flammable (except cryogenic and liquefied petroleum gases)	200
Highly toxic	Any amount
Inert and simple asphyxiant	6,000
Irritant	200
Moderately toxic	<u>20</u>
Other health hazards	650
Oxidizing (including oxygen)	504
Pyrophoric	Any amount
Radioactive	Any amount
Sensitizer	200
Toxic	Any Amount
Unstable (reactive)	Any amount

For SI: 1 cubic foot = 0.02832m³.

² Cubic feet measured at normal Temperature and pressure.

¹ Refer to Chapters 50, 53, 55, 58, 60, 63 and 64 for additional requirements and exceptions.

Amend Table 105.6.20 to read:

TABLE 105.6.20 PERMIT AMOUNTS FOR HAZARDOUS MATERIALS¹

Combustible liquids See Section 105.6.16 Corrosive materials: Seese Gases See Section 105.6.8 Liquids 55 gallons Solids 50 pounds Cryogens See Section 105.6.10 Explosive materials: See Section 105.6.14 Flammable materials: See Section 105.6.16 Gases See Section 105.6.16 Liquids See Section 105.6.16 Solids 10 pounds Highly toxic materials: Any amount Gases Any amount Liquids Any amount Moderately toxic gas 20 cubic feet Organic peroxides: Liquids: Class I-IV Liquids: Class I-IV Any Amount No Permit Required Any Amount Solids: Class I-IV No Permit Required Any Amount No Permit Required Any amount Any amount Gases 504 Cubic Feet Liquids Any amount Solids 55 gallons Solids 550 gallons Solids </th <th></th> <th>AMOUNT</th>		AMOUNT
Corrosive materials:		
Gases		See Section 105.6.16
Liquids		00
Solids 500 pounds Cryogens See Section 105.6.10 Explosive materials See Section 105.6.14 Flammable materials: See Section 105.6.8 Gases See Section 105.6.16 Solids 10 pounds Highly toxic materials: Any amount Gases Any amount Liquids Any amount Moderately toxic gas 20 cubic feet Organic peroxides: Liquids: Class I-IV Liquids: Class I-IV Any Amount No Permit Required Any Amount Solids: Class I-IV Any Amount Cases 504 Cubic Feet Liquids 501 Solids: 504 Cubic Feet Liquids 500 pounds Pyrophoric materials: 650 Cubic Feet		
Cryogens See Section 105.6.10 Explosive materials See Section 105.6.14 Flammable materials: Gases Gases See Section 105.6.8 Liquids See Section 105.6.16 Solids 10 pounds Highly toxic materials: Any amount Gases Any amount Liquids Any amount Moderately toxic gas 20 cubic feet Organic peroxides: Any Amount Liquids: Class I-IV Any Amount Solids: Class I-IV No Permit Required Any Amount No Permit Required Oxidizing materials: Gases Gases 504 Cubic Feet Liquids Any amount Solids: Any amount Other health hazards: 650 Cubic Feet Gases 650 Cubic Feet Liquids 50 pounds Pyrophoric materials: Any amount Gases Any amount Liquids Any amount Solids See Section 105.6.47 Solids Any amount	· ·	
Explosive materials Flammable materials: Gases Liquids Solids Highly toxic materials: Gases Liquids Solids Any amount No Permit Required Any Amount Solids: Class I-IV Liquids: Class I-IV Solids: Class V No Permit Required Any Amount No Permit Required Any Amount Solids: Class V No Permit Required Any amount Solids Solids Solids Pyrophoric materials: Gases Liquids Solids Any amount Any amount Any amount Solids Any amount Any a		
Flammable materials: Gases Liquids Solids Highly toxic materials: Gases Liquids Solids Highly toxic materials: Gases Liquids Solids Any amount No Permit Required Any Amount No Permit Required Any Amount No Permit Required Any amount Solids: Class I-IV Solids: Class I-V Solids: Gases Liquids Solids: Gases Solids Solids: Gases Solids Pyrophoric materials: Gases Liquids Solids Pyrophoric materials: Gases Solids Any amount Any		
Gases Liquids Solids 10 pounds Highly toxic materials: Gases Liquids Solids Highly toxic materials: Gases Liquids Solids Any amount Any amount Any amount Any amount Any amount Any amount Liquids: Class I-IV Liquids: Class I-IV Solids: Solids Gases Liquids Solids Solids Solids Pyrophoric materials: Gases Liquids Solids Solids Solids Pyrophoric materials: Gases Liquids Solids Solids Solids Solids Solids Any amount Any amount Solids Solids Solids Any amount Any amount Solids See Section 105.6.47 Solids See Section 105.6.47 Solids Any amount An		See Section 105.6.14
Liquids Solids Highly toxic materials: Gases Liquids Any amount Liquids: Class I-IV Liquids: Class I-IV Solids:		
Solids Highly toxic materials: Gases Liquids Solids Any amount Liquids: Class I-IV Liquids: Class I-IV Solids: Class I-IV Solids: Class I-IV Solids: Class V Oxidizing materials: Gases Liquids Any Amount Solids: Gases Sol4 Cubic Feet Any amount Solids Solids Pyrophoric materials: Gases Liquids Solids Any amount Solids Any amount Solids Any amount Any amount Solids Any amount Any amount Any amount Solids Any amount Any amount Any amount Any amount Any amount Solids Any amount Any amount Any amount Solids Any amount See Section 105.6.47 See Section 105.6.47 Toxic materials: Gases Liquids Gases Liquids Any amount		
Highly toxic materials: Gases Liquids Solids Any amount Liquids: Class I-IV Solids: Class I-IV Solids: Class V No Permit Required Any Amount Any amount Any amount Any amount Any amount Any amount Solids Solids Solids Any amount Solids See Section 105.6.47 Toxic materials: Gases Any amount		
Gases Liquids Solids Moderately toxic gas Organic peroxides: Liquids: Class I-IV Liquids: Class I-IV Liquids: Class I-IV Solids: Class I-IV Solids: Class I-IV Solids: Class I-IV Solids: Class V No Permit Required Any Amount No Permit Required Any Amount No Permit Required Any Amount No Permit Required Oxidizing materials: Gases Liquids Solids: Any amount Solids: Gases Liquids Solids: Gases Liquids Solids Solids Pyrophoric materials: Gases Liquids Solids Pyrophoric materials: Gases Liquids Solids Any amount Any amount Any amount Any amount Solids Any amount Any amount Any amount Solids Solids Solids Any amount Solids See Section 105.6.47 Toxic materials: Gases Any Amount		<u>10 pounds</u>
Liquids Solids Any amount Any amount Any amount Moderately toxic gas 20 cubic feet Organic peroxides: Liquids: Class I-IV Any Amount No Permit Required Solids: Class I-IV Any Amount No Permit Required Any Amount Solids: Class V No Permit Required Any Amount No Permit Required Any Amount Solids: Class V No Permit Required Any Amount Solids: Class V Solids: Class V Solids: Solids: Solids: Any amount Any amount Solids: Any amount Solids: Any amount Solids Any amount Any amount Any amount Radioactive materials: Gases Any Amount Solids See Section 105.6.47 Solids See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Any amount Any amount Any amount Solids Any amount Any amount Solids Any amount Any amount Any amount Solids Any amount Any amount Any amount Solids Any amount Any amount Any amount Any amount Solids Any amount Any amount Any amount Any amount Solids Any amount Any		
Solids Moderately toxic gas Organic peroxides: Liquids: Class I-IV Liquids: Class V Solids: Class I-IV Solids: Class V Oxidizing materials: Gases Liquids Solids: Other health hazards: Gases Liquids Solids Pyrophoric materials: Gases Liquids Solids Prophoric materials: Gases Liquids Solids Toxic materials: Gases Any amount		
Moderately toxic gas 20 cubic feet Organic peroxides: Any Amount Liquids: Class I-IV Any Amount Solids: Class I-IV Any Amount Solids: Class V No Permit Required Oxidizing materials: 504 Cubic Feet Gases 504 Cubic Feet Liquids Any amount Solids: Any amount Other health hazards: 650 Cubic Feet Gases 650 Cubic Feet Liquids 55 gallons Solids 500 pounds Pyrophoric materials: Any amount Gases Any amount Liquids Any amount Solids Any Amount Radioactive materials: Any Amount Gases Any Amount Liquids See Section 105.6.47 Toxic materials: Any amount Gases Any amount Liquids Any amount Solids Any amount Unstable (reactive) materials: Any amount Gases Any amount		
Organic peroxides: Liquids: Class I-IV Liquids: Class V Solids: Class I-IV Solids: Class I-IV Solids: Class V No Permit Required Any Amount No Permit Required Any Amount No Permit Required Oxidizing materials: Gases Liquids Solids: Other health hazards: Gases Liquids Solids Solids Pyrophoric materials: Gases Liquids Solids Pyrophoric materials: Gases Liquids Solids Any amount Solids Any amount Solids Any amount Solids Any amount Solids Solids Any amount Solids Solids Any amount Solids Any amount Solids See Section 105.6.47 Solids See Section 105.6.47 Solids Any amount Liquids See Section 105.6.47 Solids Any amount		
Liquids: Class I-IV Liquids: Class V Solids: Class I-IV Solids: Class V No Permit Required Any Amount No Permit Required Any Amount No Permit Required Any Amount No Permit Required Oxidizing materials: Gases Liquids Solids: Other health hazards: Gases Liquids Solids Other health hazards: Gases Liquids Solids Pyrophoric materials: Gases Any amount Liquids Any amount Solids Any amount Cases Liquids See Section 105.6.47 Solids See Section 105.6.47 Solids Any amount Liquids Solids Any amount Liquids Solids Any amount Liquids Solids Any amount Any amount Any amount Any amount Liquids Solids Any amount		20 cubic feet
Liquids: Class V Solids: Class I-IV Solids: Class V Oxidizing materials: Gases Liquids Solids: Gases Liquids Solids: Gases Solids: Gases Solids: Gases Any amount Solids Pyrophoric materials: Gases Liquids Solids Any amount Any amount Solids Radioactive materials: Gases Liquids Solids Solids Solids Any amount Any amount Comparison of the first of the fir		
Solids: Class I-IV Solids: Class V Oxidizing materials: Gases Liquids Solids: Gases Liquids Solids: Gases Any amount Cother health hazards: Gases Gases Any amount Solids Pyrophoric materials: Gases Any amount Liquids Solids Any amount Any amount Any amount Any amount Solids Radioactive materials: Gases Any Amount See Section 105.6.47 Solids Toxic materials: Gases Any amount See Section 105.6.47 See Section 105.6.47 Solids Toxic materials: Gases Any amount		
Solids: Class V Oxidizing materials: Gases Liquids Solids: Other health hazards: Gases Liquids Solids Other health hazards: Gases Liquids Solids Pyrophoric materials: Gases Any amount Liquids Solids Radioactive materials: Gases Liquids Solids Radioactive materials: Gases Liquids Solids Radioactive materials: Gases Any Amount Liquids Solids Radioactive materials: Gases Any Amount Liquids See Section 105.6.47 Solids Toxic materials: Gases Any amount Liquids See Section 105.6.47 Solids Toxic materials: Gases Any amount	Liquids: Class V	No Permit Required
Oxidizing materials: Gases Liquids Solids: Other health hazards: Gases Liquids Solids Gases Any amount Solids Pyrophoric materials: Gases Any amount Liquids Solids Any amount Any amount Any amount Any amount Any amount Solids Radioactive materials: Gases Liquids See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Any amount Any amount Liquids See Section 105.6.47 Solids Any amount Liquids Any amount		
Gases Liquids Solids: Other health hazards: Gases Liquids Solids Gases Any amount Solids Radioactive materials: Gases Liquids Solids Any Amount See Section 105.6.47 Solids Toxic materials: Gases Any amount		No Permit Required
Liquids Any amount Solids: Any amount Other health hazards: Gases 650 Cubic Feet Liquids 55 gallons Solids 500 pounds Pyrophoric materials: Gases Any amount Liquids Any amount Solids Any amount Radioactive materials: Gases Any Amount Liquids See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Any amount Liquids See Section 105.6.47 Solids Any amount Unstable (reactive) materials: Gases Any amount	Oxidizing materials:	
Solids: Other health hazards: Gases Liquids Solids Pyrophoric materials: Gases Liquids Solids Any amount Solids Radioactive materials: Gases Liquids Solids Any Amount See Section 105.6.47 See Section 105.6.47 Toxic materials: Gases Any amount Any amount Any amount See Section 105.6.47 Toxic materials: Gases Any amount	Gases	504 Cubic Feet
Other health hazards: Gases Liquids Solids Pyrophoric materials: Gases Any amount Liquids Solids Radioactive materials: Gases Any Amount Liquids Solids Radioactive materials: Gases Any Amount See Section 105.6.47 Solids Toxic materials: Gases Any amount See Section 105.6.47 Toxic materials: Gases Any amount Any amount Any amount Liquids Solids Any amount Any amount Any amount Any amount Any amount Unstable (reactive) materials: Gases Any amount	Liquids	Any amount
Gases Liquids Solids Pyrophoric materials: Gases Liquids Solids Any amount Liquids Solids Radioactive materials: Gases Any Amount Liquids Solids Any Amount Solids Any Amount Liquids See Section 105.6.47 Solids Toxic materials: Gases Any amount Any amount Unstable (reactive) materials: Gases Any amount		Any amount
Liquids 55 gallons 500 pounds Pyrophoric materials: Gases Any amount Any amount Solids Any amount Solids Any amount Radioactive materials: Gases Any Amount See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Any amount See Section 105.6.47 Toxic materials: Gases Any amount Any amount Any amount Solids Any amount Any amount Any amount Solids Any amount	Other health hazards:	
Solids Pyrophoric materials: Gases Liquids Solids Radioactive materials: Gases Liquids Solids Radioactive materials: Gases Any Amount See Section 105.6.47 Solids Toxic materials: Gases Liquids See Section 105.6.47 Toxic materials: Gases Any Amount See Section 105.6.47 Toxic materials: Gases Any amount Any amount Any amount Unstable (reactive) materials: Gases Any amount	Gases	650 Cubic Feet
Pyrophoric materials: Gases Liquids Solids Any amount See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Liquids Gases Any amount		55 gallons
Gases Liquids Solids Any amount See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Any amount Liquids See Section 105.6.47 Any amount Any amount Any amount Any amount Any amount Unstable (reactive) materials: Gases Any amount		500 pounds
Liquids Any amount Solids Any amount Radioactive materials: Gases Any Amount Liquids See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Any amount Liquids See Section 105.6.47 Toxic materials: Gases Any amount Any amount Any amount Any amount Unstable (reactive) materials: Gases Any amount	Pyrophoric materials:	
Solids Any amount Radioactive materials: Gases Any Amount Liquids See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Any amount Liquids Any amount	Gases	Any amount
Radioactive materials: Gases Liquids Solids See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Liquids Liquids Solids Any amount Any amount Any amount Unstable (reactive) materials: Gases Any amount	Liquids	Any amount
Gases Liquids See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Liquids Liquids Solids Any amount Any amount Any amount Any amount Unstable (reactive) materials: Gases Any amount		Any amount
Liquids See Section 105.6.47 Solids See Section 105.6.47 Toxic materials: Gases Any amount Liquids Any amount Solids Any amount Unstable (reactive) materials: Gases Any amount	Radioactive materials:	
Solids See Section 105.6.47 Toxic materials: Gases Any amount Liquids Any amount Solids Any amount Unstable (reactive) materials: Gases Any amount	Gases	
Toxic materials: Gases Any amount Liquids Solids Any amount		See Section 105.6.47
Gases Liquids Solids Any amount Any amount Any amount Unstable (reactive) materials: Gases Any amount Any amount	Solids	See Section 105.6.47
Liquids Solids Any amount Any amount Unstable (reactive) materials: Gases Any amount	Toxic materials:	
Liquids Solids Any amount Any amount Unstable (reactive) materials: Gases Any amount	Gases	Any amount
Solids Any amount Unstable (reactive) materials: Gases Any amount		
Gases Any amount		Any amount
Gases Any amount	Unstable (reactive) materials:	
		Any amount
Any amount	Liquids	Any amount
Solids Any amount		
Water reactive materials:	Water reactive materials:	·
Liquids Any amount	Liquids	Any amount
Solids Any amount		

For SI: 1 gallon = 3.785 L, 1 pound = 0.454kg.

a. 20 gallons when Table 5003.1.1(1) Note k applies and hazard identification signs in accordance with Section 2703.5 are provided for quantities of 20 gallons or less.

b. 200 pounds when Table 5003.1.1(1) Note k applies and hazard identification signs in accordance with Section 2703.5 are provided for quantities of 200 pounds or less.

Add Sec. 105.6.48 to read:

105.6.48 Radioactive Materials. To store or handle at any installation more than one microcurie (37,000 becquerel) of radioactive material not contained in a sealed source or more than 1 millicurie (37,000,000 becquerel) of radioactive material in a sealed source or sources, or any amount of radioactive material for which a specific licenses from the Nuclear Regulatory Commission is required.

105.8 ANNUAL FIRE DEPARTMENT FEES

Add Sec. 105.8 to read:

105.8 Annual Fire Department Inspection Fees Required. An annual fire inspection fee shall be paid to the City of Santa Clara for each A, B, E, F, H, I, M, R-1, R-2, R-3.1, and S occupancies in the City and for any R-3 occupancy in the City wherein a home occupation is conducted except for small family day care operations.

105.9 CERTIFIED UNIFIED PROGRAM AGENCY (CUPA) FEES

Add Sec. 105.9 to read:

105.9 Certified Unified Program Agency (CUPA) Fees. Pursuant to the appointment of the City of Santa Clara as a Certified Unified Program Agency (CUPA) by the California Environmental Protection Agency, the Fire Department is authorized to collect fees associated with the CUPA programs. The CUPA fees will be collected on an annual basis or as specified in the Santa Clara Municipal Fee Schedule.

105.10 BUILDING PLANS

Add Sec. 105.10.1 to read:

105.10.1 Review of Building Plans. The Building Inspection Division shall transmit to the Fire Department a copy of each plan submitted for the construction or alteration of those occupancies classified as A, E, H, I, R-1, R-2 and all buildings classified as a high-rise as defined in the International Building Code as well as other plans when determined by the Fire code official that review by the Fire Department is necessary to ensure and maintain a reasonable degree of fire and life safety.

Add Sec. 105.10.2 to read:

105.10.2 Building Inspection Division. In addition to the foregoing, the Building Inspection Division shall review each application for a building permit for all other occupancies and shall transmit to the Fire Department each such application and its accompanying plans if it is determined that one or more of the following facts exist:

- 1. All new commercial buildings.
- 2. Building permit plans including tenant improvements shall be routed to the Fire Department for the following occupancy groups and classifications:

Group A: A-1, A-2, A-3, A-4, A-5

Group E Group F: F-1

Group H: H-1, H-2, H-3, H-4, H-5

Group I: I-1, I-2, I-3, I-4

Group R: R-1, R-2, R-3.1, R-4

Group S; S-1

- 3. Building Permit plans for tenant improvements for all other occupancies with the exception of R-3 occupancies when the tenant improvements exceed 500 square feet in area.
- 4. Building Permit plans for spray rooms, spray booth and spraying space as regulated by Chapter 24 of the Santa Clara Municipal Fire and Environmental Code.
- 5. Fire Department Access shall be reviewed for the following:
 - A. New buildings when any portion of the building is situated more than one hundred fifty (150) feet from a public street.
 - B. Parking lot layout changes.
 - C. Vehicle gate installations.
 - D. Plan developments which include private streets.
- 6. Hazardous Materials: Building Permit plans including tenant improvements for projects intended for the use, storage or handling of hazardous materials (includes soil remediation utilizing hazardous materials) when the quantities exceed the quantities set forth in Tables 105.6.8, 105.6.10 and 105.6.20.
- 7. Storage: Building Permit plans which includes storage that may exceed ten (10) feet or includes storage of any height containing: aerosols, plastics, idle pallets, plastic pallets, rubber tires, baled cotton, rolled paper, flammable liquids or similar commodities.

Add Sec. 105.10.3 to read:

105.10.3 Transmittal. When any plans are transmitted under Section 105.10 above, the Fire code official shall review the same and determine what fire and life safety requirements are applicable. The Fire code official shall transmit the results of the plan review to the Building Inspection Division in writing.

Add Sec. 105.10.4 to read:

105.10.4 Final Approval. No final inspection under this code, as to all or any portion of the development, shall be deemed completed and no certificate of occupancy shall be issued unless and until the requirements imposed by this code have been completed and the final approval thereof, by the Fire Department, has been given as provided herein and all inspection fees paid.

Add Sec. 105.10.5 to read:

105.10.5 Expiration of Permits. Every permit issued by the Fire Department (except annual fire permits) under the provisions of this code shall expire by limitation and become null and void, if building or work authorized by such permit is not commenced within 180 days from the date of such permit, or if the building or work authorized by such permit is suspended or abandoned at any time after the work is commenced for a period of 180 days. Before work can be recommenced, a fee as specified in the City of Santa Clara Municipal Fee Schedule shall be paid to the Fire Department provided no changes have been made or will be made in the original plans and specifications for such work; and provided further that such suspension or abandonment has not exceeded one year. For permits that have been inactive for a period exceeding one-year, the permittee shall pay a new full permit fee.

A permittee holding an unexpired permit may apply for an extension of the time within which work may commence under that permit when the permittee is unable to commence work within the time required by this section for good and satisfactory reasons. The Fire code official may extend the time for action by the permittee for a period not exceeding 180 days

upon written request by the permittee showing that circumstances beyond the control of the permittee have prevented action from being taken. Permits shall not be extended more than once.

Add Sec. 105.10.6 to read:

105.10.6 Expiration Of Plan Review. Applications for which no permit is issued within 180 days following the date of application shall expire by limitation, and plans and other data submitted for review may thereafter be returned to the applicant or destroyed by the Fire Marshal. The Fire Marshal may extend the time for action by the applicant for a period not exceeding 180 days on written request by the applicant showing that circumstances beyond the control of the applicant have prevented action from being taken. An application shall not be extended more than once. An application shall not be extended if this code or any other pertinent laws or ordinances have been amended subsequent to the date of application. In order to renew action on an application after expiration, the applicant shall resubmit plans and pay the fee specified in the City of Santa Clara Municipal Fee Schedule to the Fire Department.

SECTION 106 INSPECTIONS

106.1 INSPECTION AUTHORITY

Amend Sec. 106.1 to read:

106.1 Inspection Authority. The fire code official is authorized to enter and examine any building, structure, marine vessel, vehicle or premises in accordance with Appendix chapter 1, Section 104.3 for the purpose of enforcing this code. The fire code official is authorized to inspect, as often as necessary, buildings and premises, including such other hazards or appliances designated by the fire code official for the purposes of ascertaining and causing to be corrected any conditions which would reasonably tend to cause fire or contribute to its spread, result in an unauthorized discharge of hazardous materials, or any violation of this code or any other law or standard affecting fire and life safety.

Add Sec. 106.5 to read:

106.5 Documents. Any person or party who prevents or attempts to prevent any representative of the Fire Department from examining any relevant books or records in the conduct of his or her official duties under this code shall be in violation of this code.

Add Sec. 106.6 to read:

106.6 Evidence. Any person or party who prevents or interferes with the preservation of evidence of any violation of any of the provisions of this code or of the rules and regulations promulgated pursuant to this code or any other Federal, State, or local law, rule, or regulation shall be in violation of this code.

Add Sec. 106.7 to read:

106.7 Interference. Any person or party who willfully prevents, interferes with, or attempts to hinder in any way the work of any authorized representative of the Fire Department in the lawful enforcement of any provision of this code, or fails to promptly permit entry for the purpose of inspection and examination pursuant to this code shall be in violation of this code.

SECTION 108 BOARD OF APPEALS

Amend Sec. 108.1 to read:

108.1 Appeals. Whenever the Fire Chief of the City of Santa Clara or any authorized designee disapproves an application or refuses to grant a permit applied for under the provisions of this Code, or when it is claimed that the provisions of this Code do not apply or that the true intent of meaning of the Code have been misconstrued or wrongly interpreted, the applicant may appeal the decision of the Chief to the City Manager of the City of Santa Clara within seven (7) business days from the date of the decision or interpretation.

SECTION 109 VIOLATIONS

Add Sec. 109.1.1 to read:

109.1.1 Abatement Of Fire And Life Safety Hazards By Fire Code Official. If any person fails to comply with the orders of the fire code official, or if the fire code official is unable to locate the owner, operator, occupant or other person responsible within a reasonable time, the fire code official or any authorized representative may take such steps as are necessary to abate the hazard for the protection of the public safety. In no event is notice necessary before abatement, when the hazard is a clear and present danger to the public welfare. All costs related to such abatement shall become a lien on the subject property.

Add Sec. 109.1.2 to read:

109.1.2 Criminal Or Civil Penalty For Violation; Payment Of Funds To Account. Pursuant to the City's prosecutorial discretion, the City may enforce violations of the provisions of this code in any manner authorized by this section or by any other law, including but not limited to issuance of criminal citations, referral to the District Attorney, referral to other appropriate agencies, administrative actions and civil actions.

Add Sec. 109.1.3 to read:

109.1.3 Infractions/Misdemeanors. Any person who violates any of the provisions of this code, any of the provisions of any written authority of the City Manager or his or her duly authorized agents and representatives or any provision of any permit issued pursuant to this code shall be guilty of an infraction/misdemeanor. Each and every day, or any part thereof, during which any such violation is committed, continued or allowed shall be a separate offense.

Add Sec. 109.1.4 to read:

109.1.4 Prosecution. Every violation of this code shall be a misdemeanor; provided, however, that where the City Attorney or his or her duly authorized agents has determined that such action would be in the best interest of justice, the City Attorney may specify in the accusatory pleading, citation or amendment thereto that the violation shall be prosecuted as an infraction.

Add Sec. 109.1.5 to read:

109.1.5 Penalty for Infraction. Each and every violation of this code, which is deemed an infraction, is punishable by:

(1) A fine not exceeding one hundred dollars (\$100.00) for the first violation;

- (2) A fine not exceeding two hundred dollars (\$200.00) for the second violation of the same or similar provision within one year period; or,
- (3) A fine not exceeding five hundred dollars (\$500.00) for each additional violation, after the second, of the same or similar provision of this Chapter within a one year period of the first violation.

Add Sec. 109.1.6 to read:

109.1.6 Penalty for Misdemeanor. Each and every violation of this code, which is deemed a misdemeanor, is punishable by a penalty of not more than one thousand dollars (\$1,000.00) or by imprisonment in the City or County jail for a period not exceeding six (6) months, or, by both penalty and imprisonment.

Add Sec. 109.1.7 to read:

109.1.7 Enforcement Authority. The following designated employee positions may enforce the provisions of this code by issuance of citations. Peace officers and persons employed in such positions are authorized to exercise the authority provided in Penal Code Section 836.5 and are authorized to issue citations for violations of this code. The designated employee positions are: the City Manager or his or her duly authorized agents and representatives.

Add Sec. 109.1.8 to read:

109.1.8 Civil Penalties. Any person who intentionally, accidentally or negligently violates any provision of this code, any written authority of the City Manager or his or her duly authorized agents and representatives, or any provision of any permit issued pursuant to this code may be civilly liable to the City in the sum of not less than one hundred dollars (\$100.00) but not to exceed one thousand dollars (\$1,000.00) per day for each day in which such violation occurs or continues. The City may petition the municipal or superior court to impose, assess, and recover such sums. The civil penalty provided in this Section excludes inspection costs and abatement costs, is cumulative and not exclusive, and shall be in addition to all other remedies available to the City under state and federal law and local ordinances. Funds collected pursuant to this Section shall be paid to City's Uniform Fire Code Enforcement account.

Chapter 2 DEFINITIONS

Chapter 2 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 202 GENERAL DEFINITIONS

Add the following definitions:

CONTINUOUS GAS DETECTION SYSTEM. An gas detection system where the analytical instrument is maintained in continuous operation and sampling is performed without interruption. Analysis is allowed to be performed on a cyclical basis at intervals not to exceed 30 minutes. In occupied areas where air is re-circulated and not exhausted to a treatment system (e.g. breathing zone), the fire code official may require a cyclical basis at intervals not to exceed 5 minutes. The gas detection system shall be able to detect the presence of a gas at or below the permissible exposure limit in occupiable areas and at or below ½ IDLH (or 0.05 LC 50 if no established IDLH) in unoccupiable areas.

CORROSIVE LIQUID. Corrosive liquid is

- 1) any liquid which, when in contact with living tissue, will cause destruction or irreversible alteration of such tissue by chemical action;
- any liquid having a pH of 2 or less or 12.5 or more;
- 3) any liquid classified as corrosive by the U.S. Department of Transportation; and
- 4) any material exhibiting the characteristics of corrosivity in accordance with Title 22, California Code of Regulations §66261.22.

MODERATELY TOXIC GAS. A chemical or substance that has a median lethal concentration (LC50) in air more than 2000 parts per million but not more than 5000 parts per million by volume of gas or vapor, when administered by continuous inhalation for an hour, or less if death occurs within one hour, to albino rats weighing between 200 and 300 grams each.

MAXIMUM THRESHOLD QUANTITY (MAX TQ). Maximum Threshold Quantity (Max TQ) is the maximum quantity of a moderately toxic or toxic gas, which may be stored in a single vessel before a more stringent category of regulation is applied. The following equation shall be used to calculate the Max TQ:

Max TQ (pounds) = LC50 (ppm) \times 2 lb.

For gas mixtures containing one or more toxic, highly toxic or moderately toxic components, LC50 shall be calculated using CGA Standards P-20 and P-23 as referenced in Appendix E, Section 103.1.3.1

OTHER HEALTH HAZARD MATERIAL. A hazardous material which affects target organs of the body, including but not limited to, those materials which produce liver damage, kidney damage, damage to the nervous system, act on the blood to decrease hemoglobin function, deprive the body tissue of oxygen or affect reproductive capabilities, including mutations (chromosomal damage), sensitizers or teratogens (effect on fetuses).

SECONDARY CONTAINMENT. Secondary containment is that level of containment that is external to and separate from primary containment and is capable of safely and securely containing the material, without discharge, for a period of time reasonably necessary to ensure detection and remedy of the primary containment failure.

WILDLAND-URBAN INTERFACE FIRE AREA. A geographical area identified by the state as a "Fire Hazard Severity Zone" in accordance with the Public Resources Code Sections 4201 through 4204 and Government Code Sections 51175 through 51189, or other areas designated by the enforcing agency to be at a significant risk from wildfires. See Article 86B for the applicable referenced sections of the Government Code and the Public Resources Code. The Wildland-Urban Interface Fire Area shall be defined as all areas within the City/Town of (Name of City/Town) as set forth and delineated on the map entitled "Wildland-Urban Interface Fire Area" which map and all notations, references, data and other information shown thereon are hereby adopted and made a part of this chapter. The map properly attested, shall be on file in the Office of the City/Town Clerk of the City/Town of (Name of City/Town).

WORKSTATION. A defined space or independent piece of equipment using <u>hazardous</u> <u>materials</u> <u>HPM within a fabrication area</u> where a specific function, laboratory procedure or research activity occurs. *Approved or listed* hazardous materials storage cabinets, flammable liquid storage cabinets or gas cabinets serving a work station are included as part of the work station. A work station is allowed to contain ventilation equipment, fire protection devices, detection devices, electrical devices and other processing and scientific equipment.

Chapter 3 GENERAL REQUIREMENTS

Chapter 3 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 311 VACANT PREMISES

Amend Section 311.1 to read:

311.1 General. Temporarily unoccupied buildings, structures, premises or portions thereof, including tenant spaces, shall be safeguarded and maintained in accordance with Sections 311.1 through 311.4 311.5.

SECTION 316 HAZARDS TO FIREFIGHTERS

Add Section 316.7 to read: **BUILDING STANDARD**

316.7 Roof Guardrails At Interior Courts. Roof openings into interior courts that are bounded on all sides by building walls shall be protected with guardrails. The top of the guardrail shall not be less than 42 inches in height above the adjacent roof surface that can be walked on. Intermediate rails shall be designed and spaced such that a 12-inch diameter sphere cannot pass through.

Exception:

Where the roof opening is greater than 600 square feet in area.

Chapter 4 EMERGENCY PLANNING AND PREPAREDNESS

Chapter 4 of the 2012 International Fire Code is not adopted.

Chapter 5 FIRE SERVICE FEATURES

Chapter 5 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 503 FIRE APPARATUS ACCESS ROADS

Amend Section 503.1. as follows:

503.1 Where required. Fire apparatus access roads shall be provided and maintained in accordance with Sections 503.1.1 through 503.1.2 <u>and as per Fire Department Access</u> Road Standards.

Amend Section 503.2.1 as follows:

503.2.1 Dimensions. Fire apparatus access roads shall have an unobstructed width of not less than 20 feet (6096 mm), except for approved security gates in accordance with Section 503.6, and an unobstructed vertical clearance of 13 feet 6 inches (4115 mm).

Exception:

When there are not more than two Group R, Division 3, or Group U occupancies, the access road width may be modified by the fire code official.

SECTION 504 ACCESS TO BUILDINGS AND ROOFS

Add Section 504.4 to read:

504.4 Access Control Devices. When access control devices including bars, grates, gates, electric or magnetic locks or similar devices, which would inhibit rapid fire department emergency access to within and throughout the building, are installed, such devices shall be approved by the fire code official. All electrically powered access control devices shall be provided with an approved means for deactivation or unlocking from a single location or otherwise approved by the fire department.

Access control devices shall also comply with Chapter 10 Egress.

SECTION 510 EMERGENCY RESPONDER RADIO COVERAGE

Add Section 510.1.1 as follows:

510.1.1 Obstruction by new buildings. When determined, in the opinion of the fire code official, a new structure obstructs the line of sight emergency radio communications to existing buildings or to any other locations, the developer of the structure shall provide and install the radio retransmission equipment necessary to restore communications capabilities. The equipment shall be located in an approved space or area within the new structure.

Chapter 6 BUILDING SERVICE AND SYSTEMS

Chapter 6 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 605 ELECTRICAL EQUIPMENT, WIRING AND HAZARDS

Add Section 605.12 to read:

605.12 Immersion Heaters. All electrical immersion heaters used in dip tanks, sinks, vats and similar operations shall be provided with approved over-temperature controls and low liquid level electrical disconnects. Manual reset of required protection devices shall be provided.

<u>SECTION 608 STATIONARY STORAGE BATTERY SYSTEMS</u>

Add Section 608.6.1.1 to read:

608.6.1.1 Failure of Ventilation System. Failure of the ventilation system shall automatically disengage the charging system.

Chapter 8 INTERIOR FINISH, DECORATIVE MATERIALS AND FURNISHINGS

Chapter 8 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 806 DECORATIVE VEGETATION IN NEW AND EXISTING BUILDINGS

Amend Section 806.1.1 as follows:

806.1.1 Restricted occupancies. Natural cut trees shall be prohibited in Group A, E, I-1, I-2, I-3, I-4, M, R-1, R-2 and R-4 Occupancies. Display inside buildings. The display of Christmas trees and other decorative vegetation shall be in accordance with the California Code of Regulations, Title 19, Division 1, §3.08 and Sections 806.1 through 806.5.

Exceptions:

- 1. Trees located in areas protected by an *approved automatic sprinkler system* in accordance Section 903.1.1 or 903.3.1.2 shall not be prohibited in Groups A, E, M, R-1 and R-2.
- 2. Trees shall be allowed within dwelling units in Group R-2 occupancies.

Chapter 9 FIRE PROTECTION SYSTEMS

Chapter 9 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 903 AUTOMATIC SPRINKLER SYSTEMS

Building Standard

Amend Section 903.2 to read: **BUILDING STANDARD**

903.2 Where required. Approved automatic sprinkler systems in new <u>and existing</u> buildings and structures shall be provided in the locations described in <u>this Section or in</u> Sections 903.2.1 through 903.2.18 <u>whichever is the more restrictive</u>.

For the purposes of this section, firewalls and fire barriers used to separate building areas shall be constructed in accordance with the California Building Code and shall be without openings or penetrations.

1. An automatic sprinkler system shall be installed throughout all new buildings and structures.

EXCEPTIONS:

- (a) Buildings and structures that do not exceed 1,000 square feet of building area in the following Groups: A, B, E, F, I, L, M, S and U occupancies. Exception does not apply to habitable accessory structures constructed on residential properties, regardless of area or occupancy classification.
- (b) <u>Group S-2 and U occupancies used exclusively for vehicle parking and meeting all the</u> following conditions:
 - 1. Noncombustible construction.
 - 2. Maximum building area not to exceed 5,000 square feet.
 - 3. Structure is open on three (3) or more sides.
 - 4. <u>Minimum of 10 feet separation from existing buildings unless area is separated</u> by fire walls complying with CBC Section 706.
- 2. An automatic sprinkler system shall be provided throughout existing Group A, B, E, F, I, L, M, S and U buildings and structures, when additions are made that increase the building area to more than 3,600 square feet or that create conditions described in Sections 903.2.1 through 903.2.18.
- 3. <u>An automatic sprinkler system shall be provided throughout existing Group R occupancies</u> when additions are made and the building area is greater than 3,600 square feet.
- 4. <u>An automatic sprinkler system shall be provided throughout all new basements regardless</u> of size and throughout existing basements that are expanded by more than 50%.
- 5. Any change in the character of occupancy or in use of any building with a building area equal to or greater than 3,600 square feet which, in the opinion of the fire code official or building official, would place the building into a more hazardous division of the same occupancy group or into a different group of occupancies and constitutes a greater degree of life safety¹ or increased fire risk², shall require the installation of an approved fire automatic fire sprinkler system.

- ¹ Life Safety Increased occupant load, public assembly areas, public meeting areas, churches, indoor amusement attractions, buildings with complex exiting systems due to increased occupant loads, large schools/day-care facilities, large residential care facilities with non-ambulatory
- ² Fire Risks High-piled combustible storage, woodworking operations, hazardous operations using hazardous materials, increased fuel loads (storage of moderate to highly combustible materials), increased sources of ignition (welding, automotive repair with the use of flammable liquids and open flames).

Amend Section 903.1.1 to read:

- **903.3.1.1 NFPA 13 Sprinkler Systems.** Where the provisions of this code require that a building or portion thereof be equipped throughout with an automatic sprinkler system in accordance with this section, sprinklers shall be installed throughout in accordance with NFPA 13 except as provided in Section 903.3.1.1.1.
 - 1. For new buildings having no designated use or tenant, the minimum sprinkler design density shall be Ordinary Hazard Group 2. Where future use or tenant is determined to require a higher density, the sprinkler system shall be augmented to meet the higher density.

Chapter 28 LUMBER YARDS AND WOOD WORKING FACILITIES

Chapter 28 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 2803 General Requirements

Add Section 2803.8 to read:

2803.8 Fire Protection Water Supply System. An approved fire protection water supply and hydrant system suitable for the fire hazard involved shall be provided for open storage yards and processing areas. Hydrant systems shall be installed in accordance with NFPA 24.

Chapter 33 FIRE SAFETY DURING CONSTRUCTION AND DEMOLITION

Chapter 33 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 3304 PRECAUTIONS AGAINST FIRE

Add Section 3304.8 to read:

3304.8 Fire Walls. When firewalls are required in combustible construction, the wall construction shall be completed (with all openings protected) immediately after the building is sufficiently weather-protected at the location of the wall(s).

SECTION 3311 MEANS OF EGRESS

Building Standard

Amend Section 3311.1 as follows:

[B] 3311.1 Stairways Required. Where a building has been constructed to a height greater than 50 feet (15,240 mm) or four stories, or where an existing building exceeding 50 feet (15,240 mm) in height is altered, at least one temporary lighted stairway shall be provided unless one or more of the permanent stairways are erected as the construction progresses shall be provided unless one or more of the permanent stairways are erected as the construction progresses. Each level above the first story in multi-story buildings that require two exit stairways shall be provided with at least two usable exit stairways after the floor decking is installed. The stairways shall be continuous and discharge to grade level. Stairways serving more than two floor levels shall be enclosed (with openings adequately protected) after exterior walls/windows are in place. Exit stairs in new and in existing, occupied buildings shall be lighted and maintained clear of debris and construction materials at all times.

Exception:

For multi-story buildings, one of the required exit stairs may be obstructed on not more than two contiguous floor levels for the purposes of stairway construction (i.e., installation of gypsum board, painting, flooring, etc.).

Building Standard

Add Section 3311.1.1 to read:

Section 3311.1.1 Required Means Of Egress. All buildings under construction shall have at least one unobstructed means of egress. All means of egress shall be identified in the prefire plan see Section 3308.2.

Chapter 50 HAZARDOUS MATERIALS-GENERAL PROVISIONS

Chapter 50 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 5001 GENERAL

Amend Section 5001.2.2.2 to read:

5001.2.2.2 Health Hazards The material categories listed in this section are classified as health hazards. A material with a primary classification as a health hazard can also pose a physical hazard.

- 1. Highly toxic and toxic materials.
- 2. Corrosive materials.
- 3. Moderately toxic gas.
- 4. Other health hazards.

SECTION 5003 GENERAL REQUIREMENTS

Add Section 5003.1.3.1 to read:

5003.1.3.1 Toxic, Highly Toxic, Moderately Toxic Gases And Similarly Used Or Handled Materials. The storage, use and handling of toxic, highly toxic and moderately toxic gases in amounts exceeding Table 6004.2 or 6004.3 shall be in accordance with this chapter and Chapter 60. Any toxic, highly toxic or moderately toxic material that is used or handled as a gas or vapor shall be in accordance with the requirements for toxic, highly toxic or moderately toxic gases.

Add Section 5003.1.5 to read:

5003.1.5 Other Health Hazards. The storage, use and handling of materials classified as other health hazards including carcinogens, irritants and sensitizers in amounts exceeding 810 cubic feet for gases, 55 gallons for liquids and 5,000 pounds for solids shall be in accordance with Section 5003.

Add Section 5003.1.6 to read:

5003.1.6 Spill Control and Secondary Containment Requirements. A containment system shall be required for all hazardous materials, which are liquids or solids at normal temperature, and pressure (NTP) where a spill is determined to be a plausible event and where such an event would endanger people, property or the environment. Construction shall be substantial, capable of safely and securely containing a sudden release without discharge. Design criteria shall be performance oriented and constructed of physically and chemically compatible materials to resist degradation and provide structural and functional integrity for a period of time reasonably necessary to ensure detection, mitigation, and repair of the primary system. **Regardless of quantities, spill control and secondary containment shall also comply with Section 5004.2.**

Amend Sec. 5003.2.2.1 to read:

5003.2.2.1 Design and Construction. Piping, tubing, valves, fittings and related components used for hazardous materials shall be in accordance with the following:

 Piping, tubing, valves, fittings and related components shall be designed and fabricated from materials compatible with the material to be contained and shall be of adequate

- strength and durability to withstand the pressure, structural and seismic stress, and exposure to which they are subject.
- 2. Piping and tubing shall be identified in accordance with ASME A13.1 <u>and the Santa Clara County Fire Chiefs Marking Requirements and Guidelines for Hazardous Materials and Hazardous Waste to indicate the material conveyed.</u>
- 3. Readily accessible manual valves or automatic remotely activated fail-safe emergency shutoff valves shall be installed on supply piping and tubing at the following locations:
 - 1. The point of use.
 - 2. The tank, cylinder or bulk use.
- 4. Manual emergency shutoff valves and controls for remotely activated emergency shutoff valves shall be identified and the location shall be clearly visible accessible and indicated by means of a sign.
- 5. Backflow prevention or check valves shall be provided when the backflow of hazardous materials could create a hazardous condition or cause the unauthorized discharge of hazardous materials.
- 6. Where gases or liquids having a hazard ranking of:

Health hazard Class 3 or 4

Flammability Class 4

Reactivity Class 4

in accordance with NFPA 704 are carried in pressurized piping above 15 pounds per square inch gauge (psig)(103 Kpa), an approved means of leak detection, emergency shutoff and excess flow control shall be provided. Where the piping originates from within a hazardous material storage room or area, the excess flow control shall be located within the storage room or area. Where the piping originates from a bulk source, the excess flow control shall be located as close to the bulk source as practical.

Exceptions:

- 1. Piping for inlet connections designed to prevent backflow.
- 2. Piping for pressure relief devices.
- 7. Secondary containment or equivalent protection from spills shall be provided for piping for liquid hazardous materials and for highly toxic and toxic corrosive gases above threshold quantities listed in Tables 6004.2 and 6004.3. Secondary containment includes, but is not limited to double walled piping.

Exceptions:

- 1. <u>Secondary containment is not required for toxic corrosive gases if the piping is</u> constructed of inert materials.
- 2. <u>Piping under sub-atmospheric conditions if the piping is equipped with an alarm and fail-safe-to-close valve activated by a loss of vacuum.</u>
- 8. Expansion chambers shall be provided between valves whenever the regulated gas may be subjected to thermal expansion. Chambers shall be sized to provide protection for piping and instrumentation and to accommodate the expansion of regulated materials.

Amend Section 5003.2.2.2 to read:

5003.2.2.2 Additional Regulation for Supply Piping for Health Hazard Materials. Supply piping and tubing for gases and liquids having a health hazard ranking of 3 or 4 shall be in accordance with ASME B31.3 and the following:

1. Piping and tubing utilized for the transmission of toxic, highly toxic, or highly volatile corrosive liquids and gases shall have welded, threaded or flanged brazed connections throughout except for connections within an ventilated exhausted enclosure if the material is a gas, or an approved method of drainage or containment is provided for connections if the material is a liquid.

2. Piping and tubing shall not be located within corridors, within any portion of a means of egress required to be enclosed in fire-resistance-rated construction or in concealed spaces in areas not classified as Group H Occupancies.

EXCEPTION:

Piping and tubing within the space defined by the walls of corridors and the floor or roof above or in concealed space above other occupancies when installed in accordance with Section 415.8.6.3 of the California Building Code as required for Group H, Division 5 Occupancies.

3. All primary piping for toxic, highly toxic and moderately toxic gases shall pass a helium leak test of 1x10-9 cubic centimeters/second where practical, or shall pass testing in accordance with an approved, nationally recognized standard. Tests shall be conducted by a qualified "third party" not involved with the construction of the piping and control systems.

Amend Section 5003.3.1 as follows:

5003.3.1 Unauthorized Discharges. When hazardous materials are released in quantities reportable under state, federal or local regulations <u>or when there is release or a threatened release that presents a threat to health, property or the environment, the fire code official shall be notified <u>immediately in an approved manner</u> and the following procedures required in accordance with Sections 5003.3.1.1 through 5003.3.1.4.</u>

Add Sec. 5003.5.2 to read:

5003.5.2 Ventilation Ducting. Product conveying ducts for venting hazardous materials operations shall be labeled with the hazard class of the material being vented and the direction of flow.

Add Sec. 5003.5.3 to read:

5003.5.3 "H" Occupancies. In "H" occupancies, all piping and tubing may be required to be identified when there is any possibility of confusion with hazardous materials transport tubing or piping. Flow direction indicators are required.

Add Sec. 5003.9.11 to read:

5003.9.11 Fire Extinguishing Systems For Workstations Dispensing, Handling or Using Hazardous Materials. Combustible and non-combustible workstations, which dispense, handle or use hazardous materials, shall be protected by an approved automatic fire extinguishing system in accordance with Section 2703.10.

Exception:

Internal fire protection is not required for Biological Safety Cabinets that carry NSF/ANSI certification where quantities of flammable liquids in use or storage within the cabinet do not exceed 500ml.

SECTION 5004 STORAGE

Amend Section 5004.2.1 as follows:

5004.2.1 Spill Control for Hazardous Material Liquids. Rooms, buildings or areas used for storage of hazardous material liquids in individual vessels having a capacity of more than 55 gallons (208 L) or in which aggregate capacity of multiple vessels exceeds 1,000 gallons (3785 L), shall be provided with spill control to prevent the flow of liquids to adjoining areas. Floors in indoor locations and similar surfaces in outdoor locations shall

be constructed to contain a spill from the largest single vessel by one of the following methods:

- 1. Liquid-tight sloped or recessed floors in indoor locations or similar areas in outdoor locations.
- 2. Liquid-tight floors in indoor locations or similar areas provided with liquid-tight raised or recessed sills or dikes.
- 3. Sumps and collection systems.
- 4. Other approved engineered systems.

Except for surfacing, the floors, sills, dikes, sumps and collection systems shall be constructed of noncombustible material, and the liquid-tight seal shall be compatible with the material stored. When liquid-tight sills or dikes are provided, they are not required at perimeter openings having an open-grate trench across the opening that connects to an approved collection system.

Amend Section 5004.2.2 as follows:

5004.2.2 Secondary Containment for Hazardous Material Liquids and Solids. Buildings, rooms or areas used for the storage of hazardous materials liquids or solids shall be provided with secondary containment in accordance with this section. when the aggregate capacity of the multiple vessels exceeds the following:

- 1. <u>Liquids: Capacity of an individual vessel exceeds 55 gallons (208 L) or the aggregate capacity of multiple vessels exceeds 1,000 gallons (3785 L); and</u>
- 2. <u>Solids: Capacity of an individual vessel exceeds 550 pounds (250 kg) or the aggregate capacity of multiple vessels exceeds 10,000 pounds (4540 kg).</u>

Delete Table: 5004.2.2 REQUIRED SECONDARY CONTAINMENT FOR HAZARDOUS MATERIAL SOLIDS AND LIQUIDS STORAGE

Amend Section 5004.2.2.2 as follows:

5004.2.2.2 Incompatible Materials. Incompatible materials used in open systems shall be separated from each other in the independent secondary containment systems.

Chapter 56 EXPLOSIVES AND FIREWORKS

Chapter 56 of the 2012 International Fire Code is not adopted with the exception of the following Sections:

Amend Section 5601.1 to read:

5601.1 Scope. For explosives requirements see California Code of Regulations, Title 19, Division 1, Chapter 10 <u>and section 5601.2 of this chapter.</u> For fireworks requirements see California Code of Regulations, Title 19, Division 1, Chapter 6 <u>and section 5601.3 of this chapter.</u> For small arms ammunition, see Section 5601.5 of this chapter.

Exceptions:

- 1. The armed Forces of the United States, Coast Guard or National Guard.
- 2. Explosives in forms prescribed by the official United States Pharmacopoeia.
- 3. The possession, storage and use of small arms ammunition when packaged in accordance with DOTn packaging requirements.
- 3. The use of explosive materials by federal, state and local regulatory, law enforcement and fire agencies acting in their official capacities.
- 4. Items preempted by federal regulations.

Add Section 5601.2 is to read:

<u>5601.2 Explosives.</u> The possession, manufacture, storage, sale, handling, and use of explosives are prohibited.

Add Section 5601.3 is to read:

5601.3 Fireworks. The possession, manufacture, storage, sale, handling, and use of fireworks, including those fireworks classified as Safe and Sane by the California State Fire Marshal, are prohibited.

Exceptions:

- 1. Storage, handling and use of fireworks and pyrotechnic special effects outside of buildings when used for public or proximate audience displays, motion picture, television, theatrical and group entertainment productions and when in accordance with Title 19 of the California Code of Regulations.
- Storage, handling and use of pyrotechnic special effects fireworks inside of buildings when used for proximate audience displays or special effects in theatrical, television, motion picture and group entertainment productions when in accordance with Title 19 of the California Code of Regulations and when in buildings equipped throughout with an approved fire sprinkler system.

Add Section 5601.4 is to read:

5601.4 Rocketry. The storage, handling, and use of model rockets shall be in accordance with Title 19 of the California Code of Regulations and as approved by the fire code official.

Add Sections 5601.5 to read:

<u>5601.5 Small Arms Ammunition-General.</u> Indoor storage and display of black powder, smokeless propellants and small arms ammunition shall comply with Sections 5601.5.1 through 5601.5.4.2.3.

Add Sections 5601.5.1 to read:

<u>5601.5.1 Packages.</u> Smokeless propellants shall be stored in approved shipping containers conforming to DOTn 49 CFR, Part 173.

Add Sections 5601.5.1.1 to read:

<u>5601.5.1.1</u> Repackaging. The bulk repackaging of smokeless propellants, black powder and small arms primers shall not be performed in retail establishments.

Add Sections 5601.5.1.2 to read:

5601.5.1.2 Damaged packages. Damaged containers shall not be repackaged.

Exception: Approved repackaging of damaged containers of smokeless propellant into containers of the same type and size as the original container.

Add Sections 5601.5.2 to read:

<u>5601.5.2</u> Storage in Group R occupancies. The storage of small arms ammunition in Group R occupancies shall comply with Sections 5601.5.2.1 through 5601.5.2.3.

Add Sections 5601.5.2.1 to read:

5601.5.2.1 Smokeless propellants. Smokeless propellants intended for personal use in quantities not exceeding 20 pounds (9 kg) are permitted to be stored in Group R-3 occupancies where kept in original containers. Smokeless powder in quantities exceeding 20 pounds (9 kg) but not exceeding 50 pounds (23 kg) are permitted to be stored in Group R-3 occupancies where kept in a wooden box or cabinet having walls of at least 1 inch (25 mm) nominal thickness.

Add Sections 5601.5.2.2 to read:

<u>5601.5.2.2</u> Black powder. Black powder intended for personal use in quantities not exceeding 20 pounds (9 kg) are permitted to be stored in Group R-3 occupancies where kept in original containers and stored in a wooden box or cabinet having walls of at least 1 inch (25 mm) nominal thickness.

Add Sections 5601.5.2.3 to read:

<u>5601.5.2.3 Small arms primers.</u> No more than 10,000 small arms primers shall be stored in Group R-3 occupancies.

Add Sections 5601.5.3 to read:

<u>5601.5.3 Display and storage in Group M occupancies.</u> The display and storage of small arms ammunition in Group M occupancies shall comply with Sections 5601.5.3.1 through 5601.5.3.2.3.

Add Sections 5601.5.3.1 to read:

<u>5601.5.3.1 Display.</u> The display of small arms ammunition in Group M occupancies shall comply with Sections 5601.5.3.1.1 through 5601.5.3.1.3.

Add Sections 5601.5.3.1.1 to read:

<u>5601.5.3.1.1</u> <u>Smokeless propellant.</u> No more than 20 pounds (9 kg) of smokeless propellants, each in containers of 1 pound (0.454 kg) or less capacity, shall be displayed in Group M occupancies.

Add Sections 5601.5.3.1.2 to read:

<u>5601.5.3.1.2</u> Black powder. No more than 1 pound (0.454 kg) of black powder shall be displayed in Group M occupancies.

Add Sections 5601.5.3.1.3 to read:

<u>5601.5.3.1.3 Small arms primers.</u> No more than 10,000 small arms primers shall be <u>displayed in Group M occupancies.</u>

Add Sections 5601.5.3.2 to read:

<u>5601.5.3.2 Storage.</u> The storage of small arms ammunition in Group M occupancies shall comply with Sections 5601.5.3.2.1 through 5601.5.3.2.3.

Add Sections 5601.5.3.2.1 to read:

<u>5601.5.3.2.1</u> <u>Storage of Smokeless propellant.</u> Commercial stocks of smokeless propellants not on display shall not exceed 100 pounds (45 kg). Quantities exceeding 20 pounds (9 kg), but not exceeding 100 pounds (45 kg) shall be stored in portable wooden boxes having walls of at least 1 inch (25 mm) nominal thickness.

Add Sections 5601.5.3.2.2 to read:

<u>5601.5.3.2.2</u> Black powder. Commercial stocks of black powder not on display shall not exceed 50 pounds (23 kg) and shall be stored in a type 4 indoor magazine. When black powder and smokeless propellants are stored together in the same magazine, the total quantity shall not exceed that permitted for black powder.

Add Sections 5601.5.3.2.3 to read:

<u>5601.5.3.2.3 Small arms primers.</u> Commercial stocks of small arms primers not on display shall not exceed 750,000. Storage shall be arranged such that not more than 100,000 small arms primers are stored in any one pile and piles are at least 15 feet (4572 mm) apart.

Chapter 57 FLAMMABLE AND COMBUSTIBLE LIQUIDS

Chapter 57 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 5704 STORAGE

Amend section 5704.2.7.5.8 to read:

5704.2.7.5.8 Overfill Prevention. An approved means or method in accordance with Section 3404.2.9.6.6 shall be provided to prevent the overfill of all Class I, II and IIIA liquid storage tanks. Storage tanks in refineries, bulk plants or terminals regulated by Sections 5706.4 or 5706.7 shall have overfill protection in accordance with API 2350.

An approved means or method in accordance with Section 5704.2.9.7.6 shall be provided to prevent the overfilling of Class IIIB liquid storage tanks connected to fuel-burning equipment inside buildings.

Exception: Outside aboveground tanks with a capacity of 1320 gallons (5000 L) or less.

Add section 5704.2.7.5.9 to read:

5704.2.7.5.9 Automatic Filling of Tanks. Systems that automatically fill flammable or combustible liquid tanks shall be equipped with overfill protection, approved by the fire code official that sends an alarm signal to a constantly attended location and immediately stops the filling of the tank. The alarm signal and automatic shutoff shall be tested on an annual basis and records of such testing shall be maintained on-site for a period of five (5) years.

Chapter 60 HIGHLY TOXIC AND TOXIC MATERIALS

Chapter 60 of the 2012 International Fire Code is adopted with the following amendments:

SECTION 6001 GENERAL

Add Sec. 6001.3 to read:

6001.3 Moderately Toxic Gases With a LC50 Equal To Or Less Than 3000 Parts Per Million. Notwithstanding the hazard class definition in Section 3702, moderately toxic gases with an LC50 less than 3000 parts per million shall additionally comply with the requirements for toxic gases in Section 6004 of this code.

Amend Sec. 6004 to read:

SECTION 6004 HIGHLY TOXIC, TOXIC AND MODERATELY TOXIC COMPRESSED GASES INCLUDING THOSE USED AS REFRIGERANTS.

Add Sec. 6004.1.4 to read:

6004.1.4 Automatic Shut-Off Valve. An automatic shut-off valve, which is of a fail-safe to close design, shall be provided to shut off the supply of highly toxic gases for any of the following:

- 1. Activation of a manual fire alarm system.
- 2. Activation of the gas detection system.
- 3. Failure of emergency power.
- 4. Failure of primary containment.
- Seismic activity.
- 6. Failure of required ventilation.
- 7. Manual activation at an approved remote location.

Add Sec. 6004.1.5 to read:

6004.1.5 Emergency Control Station. Signals from emergency equipment used for highly toxic gases shall be transmitted to an emergency control station or other approved monitoring station, which is continually staffed by trained personnel.

Add Sec. 6004.1.6 to read:

6004.1.6 Maximum Threshold Quantity. Toxic gases stored or used in quantities exceeding the maximum threshold quantity in a single vessel per control area or outdoor control area shall comply with the additional requirements for highly toxic gases of Section 6004 of this code.

Moderately toxic gases stored or used in quantities exceeding the maximum threshold quantity in a single vessel per control area or outdoor control area shall comply with the additional requirements for toxic gases of Section 6004 of this code.

Add Section 6004.1.7 to read:

6004.1.7 Reduced Flow Valve. All containers of materials other than lecture bottles containing Highly Toxic material and having a vapor pressure exceeding 29 psia shall be equipped with a reduced flow valve when available. If a reduced flow valve is not available, 10-25-13

the container shall be used with a flow-limiting device. All flow limiting devices shall be part of the valve assembly and visible to the eye when possible; otherwise, they shall be installed as close as possible to the cylinder source.

Add Section 6004.1.8 to read:

6004.1.8 Fire Extinguishing Systems. Buildings and covered exterior areas for storage and use areas of materials regulated by this Chapter shall be protected by an automatic fire sprinkler system in accordance with NFPA 13. The design of the sprinkler system for any room or area where highly toxic, toxic and moderately toxic gases are stored, handled or used shall be in accordance with Section 5004.5.

Add Section 6004.1.9 to read:

6004.1.9 Local Gas Shut Off. Manual activation controls shall be provided at locations near the point of use and near the source, as approved by the fire code official. The fire code official may require additional controls at other places, including, but not limited to, the entry to the building, storage or use areas, and emergency control stations. Manual activated shut-off valves shall be of a fail-safe-to-close design.

Add Section 6004.1.10 to read:

6004.1.10 Exhaust Ventilation Monitoring. For highly toxic gases and toxic gases exceeding threshold quantities, a continuous monitoring system shall be provided to assure that the required exhaust ventilation rate is maintained. The monitoring system shall initiate a local alarm. The alarm shall be both visual and audible and shall be designed to provide warning both inside and outside of the interior storage, use, or handling area.

Add Section 6004.1.11 to read:

6004.1.11 Emergency Response Plan. If the preparation of an emergency response plan for the facility is not required by any other law, responsible persons shall prepare, or cause to be prepared, and filed with the fire code official, a written emergency response plan. If the preparation of an emergency response plan is required by other law, a responsible person shall file a copy of the plan with the fire code official.

Add section 6004.1.12 to read:

6004.1.12 Cylinder Leak Testing. Cylinders shall be tested for leaks immediately upon delivery and again immediately prior to departure. Testing shall be approved by the fire code official in accordance with appropriate nationally recognized industry standards and practices, if any. Appropriate remedial action shall be immediately undertaken when leaks are detected.

Add Sec. 6004.1.13 to read:

6004.1.13 Inert Gas Purge System. Gas systems shall be provided with dedicated inert gas purge systems. A dedicated inert gas purge system may be used to purge more than one gas, provided the gases are compatible. Purge gas systems inside buildings shall be located in an approved gas cabinet unless the system operates by vacuum demand.

Add Sec. 6004.1.14 to read:

6004.1.14 Seismic Shutoff Valve. An automatic seismic shut-off valve, which is of a fail-safe to close design, shall be provided to shutoff the supply of highly toxic, toxic and moderately toxic gases with an LC_{50} less than 3000 parts per million upon a seismic event

within 5 seconds of a horizontal sinusoidal oscillation having a peak acceleration of 0.3G (1.47m/sec²) and a period of 0.4 seconds.

Amend Section 6004.2 to read:

6004.2 Indoor Storage and Use. The indoor storage or use of highly toxic, and toxic and moderately toxic compressed gases shall be in accordance with Sections 6004.2.1 through 6004.2.2.10.3.3. The threshold quantity for highly toxic, toxic and moderately toxic gases for indoor storage and use are set forth in Table 6004.2.

Add Table 6004.2 to read:

Threshold Quantities for Highly Toxic, Toxic and Moderately Toxic Gases for Indoor Storage and Use		
Highly Toxic	0	
Toxic	10 cubic feet	
Moderately Toxic	20 cubic feet	

Amend Section 6004.2.1 to read:

6004.2.1 Applicability. The applicability of regulations governing the indoor storage and use of highly toxic, toxic, and moderately toxic compressed gases shall be as set forth in Sections 3704.2.1.1 through 3704.2.1.3.

Amend Sec. 6004.2.1.1 to read:

6004.2.1.1 Quantities Not Exceeding the Maximum Allowable Quantity per Control Area. The indoor storage or use of highly toxic, and toxic and moderately toxic gases in amounts exceeding the maximum allowable quantity per control area set forth in Table 5003.1.1(2) Table 6004.2 shall be in accordance with Sections 5001, 5003, 6001, and 6004.1 and 6004.2.

Amend Sec. 6004.2.2 to read:

6004.2.2 General Indoor Requirements. The general requirements applicable to the indoor storage and use of highly toxic and toxic compressed gases shall be in accordance with Sections 6004.2.2.1 through 6004.2.2.10.3.

Moderately toxic gases with an LC₅₀ less than 3000 parts per million shall comply with the requirements for toxic gases in Sections 6004.2.2.1 through 6004.2.2.10.3

All other moderately toxic gases exceeding the threshold quantity shall comply with the requirements for toxic gases in Sections 6004.2.2.1 through 6004.2.2.7.

Amend Sec. 6004.2.2.7 to read:

6004.2.2.7 Treatment Systems. The exhaust ventilation from gas cabinets, exhausted enclosures and gas rooms and local exhaust systems required in Section 6004.2.2.4 and 6004.2.2.5 shall be directed to a treatment system. The treatment system shall be utilized to handle the accidental release of gas and to process exhaust ventilation. The treatment system shall be designed in accordance with Sections 6004.2.2.7.1 through 6004.2.2.7.5 and Section 510 of the California Mechanical Code.

Exceptions:

1. Highly toxic, and toxic and moderately toxic gases storage. A treatment system is not required for cylinders, containers and tanks in storage when all of the following are provided:

- 1.1. Valve outlets are equipped with gas-tight outlet plug or caps.
- 1.2. Hand wheel-operated valves have handles secured to prevent movement.
- 1.3. Approved containment vessels or containment systems are provided in accordance with Section 6004.2.2.3.
- 2. Toxic gas-use. Treatment systems are not required for toxic gases supplied by cylinders or portable tanks not exceeding 1,700 pounds (772 kg) water capacity when the following are provided:
 - 2.1. A listed or approved gas detection system with a sensing interval not exceeding 5 minutes.
 - 2.2. A listed or approved automatic-closing fail-safe valve located immediately adjacent to cylinder or portable tank valves. The fail-safe valve shall close when gas is detected at the personal exposure limit (PEL) by a gas detection system monitoring the exhaust system at the point of discharge from the gas cabinet, exhausted enclosure, ventilated enclosure or gas room. The gas detection system shall comply with Section 6004.2.2.10.

Amend 6004.2.2.10.2 to read:

6004.2.2.10.2. Alarms. The gas detection system shall initiate a local alarm and transmit a signal to a constantly attended control station when a short-term hazard condition is detected. The alarm shall be both visual and audible and shall provide warning both inside and outside the area where the gas is detected. The audible alarm shall be distinct from all other alarms.

Exception:

Signal transmission to a constantly attended control station is not required where not more than one cylinder of highly toxic or toxic gas is stored.

Amend Section 6004.3 to read:

6004.3 Outdoor Storage and Use. The outdoor storage or use of highly toxic, and toxic and moderately toxic compressed gases shall be in accordance with Sections 6004.3.1 through 6004.3.4. The threshold quantity for highly toxic, toxic and moderately toxic gases for outdoor storage and use are set forth in Table 6004.3.

Add Table 6004.3 to read:

Threshold Quantities for Highly Toxic, Toxic and Moderately Toxic Gases for Outdoor Storage and Use	
Highly Toxic	0
Toxic	10 cubic feet
Moderately Toxic	20 cubic feet

Amend Section 6004.3.1 to read:

6004.3.1 Applicability. The applicability of regulations governing the outdoor storage and use of highly toxic, toxic, <u>and moderately toxic</u> compressed gases shall be as set forth in Sections 6004.3.1.1 through 6004.3.1.3.

Amend Section 6004.3.1.1

6004.3.1.1 Quantities not Exceeding the Maximum Allowable Quantity per Control Area. The outdoor storage or use of highly toxic and toxic gases in amounts exceeding the threshold quantity per control area set forth in Table 6004.3 shall be in accordance with Sections 5001, 5003, 6001, 6004.1, and 6004.3.

Moderately toxic gases with an LC50 less than 3000 parts per million in amounts exceeding the threshold quantity in Table 6004.3 shall comply with the requirements for toxic gases in Sections 5001, 5003, 6001, 6004.1 and 6004.3.

Moderately toxic gases in amounts exceeding the threshold quantity in Table 6004.3 shall comply with the requirements for toxic gases in Sections 5001, 5003, 6001, 6004.1 and 6004.3.2.1 through 6004.3.2.5.

Amend Section 6004.3.3 to read:

6004.3.3 Outdoor Storage Weather Protection For Portable Tanks and Cylinders. Weather protection in accordance with Section 5004.13 shall be provided for portable tanks and cylinders located outdoors and not within gas cabinets or exhausted enclosures. The storage area shall be equipped with an approved automatic sprinkler system in accordance with Section 903.3.1.1 5004.5.

Exception: An automatic sprinkler system is not required when:

- 1. All materials under the weather protection structure, including hazardous materials and the containers in which they are stored, are noncombustible.
- 2. The weather protection structure is located not less than 30 feet (9144mm) from combustible materials or structures or is separated from such materials or structures using afire barrier complying with Section 6004.3.2.1.1.

Chapter 64 PYROPHORIC MATERIALS

Chapter 64 of the 2012 International Fire Code is adopted with the following amendments:

Add Section 6405.3.1 to read:

6405.3.1 Silane distribution systems automatic shutdown. Silane distribution systems shall automatically shut down at the source upon activation of the gas detection system at levels above the alarm level and/or failure of the ventilation system for the silane distribution system.